

To / 致:

Company / 公司: Yuncheng Solar Technology Co., Ltd.

Contact / 联系人: Ms. Miao Lingzhu

Email / 邮箱: Mary.miao@sunova-solar.com

From / 自:

Company / 公司: TÜV NORD (HANGZHOU) CO., LTD. / 杭州汉德质量认证服务有限公司

Contact / 联系人: Ms. Serena.Wu / 郭玉婷 小姐

Email / 邮箱: sewu@tuv-nord.com

Subject: Announcement of cancellation

主题: 证书取消通知

File No.: PVP07133/24P-03

项目号:

License holder: Yuncheng Solar Technology Co., Ltd.

持证人:

Certificate No.: 44 780 24 406749 - 148R3A1M8

证书号:

Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

产品: 地面用晶体硅光伏组件

Herewith it is declared, that the above noted certificate(s) has (have) been invalidated since 2024-12-06.

特此声明, 上述证书自 2024 年 12 月 6 日起失效。

The cancellation is due to:

取消原因:

License holder applied for cancellation.

持证人申请取消。

New certificate(s) (no: 44 780 24 406749 - 148R4A1M8) has (have) been issued to replace the cancelled one(s).

新证书 (证书号: 44 780 24 406749 - 148R4A1M8) 签发, 取代旧证书。

Certificate(s) is (are) expired.

证书有效期满。

Certificate(s) has (have) been suspended for one year, and the factory inspection, verification, and rectification required to restore the certificate(s) has (have) not been completed.

证书暂停满一年, 未完成恢复证书所需厂检、核查、整改等。

Certificate(s) has (have) been suspended for one year, and the annual certificate fee has (have) not been paid.

证书暂停满一年, 未支付证书年费。

Others: _____

其他情况: _____

Please pay attention to stop using the invalid certificate(s) from 2024-12-06. Meanwhile, please send back the original copies of above mentioned certificate(s) to us.

请注意从 2024 年 12 月 6 日开始停止使用无效证书。同时，请将上述证书原件寄回给我们。

TÜV NORD reserved the right of final explanation about the cancellation of certificate(s). TÜV NORD will not take any responsibility for the circumstance of misusing the invalid certificate(s) by the license holder or the manufacturer.

TÜV NORD 保留对证书取消的最终解释权。TÜV NORD 对证书持有者或制造商滥用无效证书的情况不承担任何责任。

Renewable Energy / 可再生能源

TÜV NORD (Hangzhou) Co., Ltd. / 杭州汉德质量认证服务有限公司



Serena.Wu / 邬玉婷

Technical Support / 技术支持

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

Yuncheng Solar Technology Co., Ltd.

Building H, Phase II, Standard Workshop, Runzhou Road, Huishan
Industrial Transformation and Agglomeration Area 214115 Wuxi,
Jiangsu Province, P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules



Valid from: 2024-12-06

Valid until: 2029-04-15

Certification program:	P12-VA-01 Rev. 17 09.20
Certification fundamental(s):	IEC 61215-1:2021 / EN IEC 61215-1:2021; IEC 61215-1-1:2021 / EN IEC 61215-1-1:2021; IEC 61215-2:2021 / EN IEC 61215-2:2021; IEC 61730-1:2023; IEC 61730-2:2023.
Registered No.:	44 780 24 406749 - 148R4A1M8
Manufacturer and factory(-ies):	See Annex 1
Test Report No.:	492013048.011
File No.:	PVP10069/24P-01



TÜV NORD CERT GmbH
Certification Body
Consumer Products



Essen, 2024-12-06

Please also pay attention to the information stated overleaf.

Manufacturer and factory(-ies):

Manufacturer:	Yuncheng Solar Technology Co., Ltd. Building H, Phase II, Standard Workshop, Runzhou Road, Huishan Industrial Transformation and Agglomeration Area 214115 Wuxi, Jiangsu Province, P.R. China
Factory 1:	Yuncheng Solar Technology Co., Ltd. Building H, Phase II, Standard Workshop, Runzhou Road, Huishan Industrial Transformation and Agglomeration Area 214115 Wuxi, Jiangsu Province, P.R. China
Factory inspection report no.:	862010664.003
Factory 2:	Anji Technology Co., Ltd. No. 19, Keji 5th Road Annan District 70955 Tainan City
Factory inspection report no.:	862010855.001
Factory 3:	PT THORNOVA SOLAR INDONESIA Jalan Hang Kesturi Kabil , Desa/Kelurahan Batu Besar, Kec. Nongsa, Kota Batam, Provinsi Kepulauan Riau, 29466, Indonesia
Factory inspection report no.:	862011037.001

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:

Double Glass PV Modules with Half-cut 182mm TOPCon Mono-crystalline Silicon Solar Cells:

156 cells: TS-BGT78(xxx) (xxx=610-635, in steps of 5)

156 cells: SS-BGxxx-78MDH(T) (xxx=610-635, in steps of 5)

144 cells: TS-BGT72(xxx)(xxx=565-605, in steps of 5)

144 cells: SS-BGxxx-72MDH(T) (xxx=565-605, in steps of 5)

132 cells: TS-BGT66(xxx) (xxx=520-555, in steps of 5)

132 cells: SS-BGxxx-66MDH(T) (xxx=520-555, in steps of 5)

120 cells: TS-BGT60(xxx) (xxx=470-505, in steps of 5)

120 cells: SS-BGxxx-60MDH(T) (xxx=470-505, in steps of 5)

108 cells: TS-BGT54(xxx) (xxx=425-450, in steps of 5)

108 cells: SS-BGxxx-54MDH(T) (xxx=425-450, in steps of 5)

96 cells: TS-BGT48(xxx) (xxx = 375-390, in steps of 5)

96 cells: SS-BGxxx-48MDH(T) (xxx = 375-390, in steps of 5)

72 cells: TS-BGT36(xxx) (xxx=280-290, in steps of 5)

72 cells: SS-BGxxx-36MDH(T) (xxx=280-290, in steps of 5)

Remark: xxx indicates rated output power generated from front side only at STC.

Maximum system voltage: 1500V

Maximum overcurrent protection rating: 30A

Electrical protection class: Class II

Pollution degree: 1

98th percentile module operating temperature (T₉₈) 70°C

Design load (positive / negative): 3600Pa / 1600Pa or 4733Pa / 1600Pa, refer CDF for details

Safety factors: 1.5

Fire safety class: Class A or Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Module types:

Double Glass PV Modules with Half-cut 210mm TOPCon Mono-crystalline Silicon Solar Cells:

132 cells: TS-BGT66(xxx)-G12 (xxx=680-730, in steps of 5)

132 cells: SS-BGxxx-66MDH-G12(T) (xxx=680-730, in steps of 5)

120 cells: TS-BGT60(xxx)-G12 (xxx=615-660, in steps of 5)

120 cells: SS-BGxxx-60MDH-G12(T) (xxx=615-660, in steps of 5)

56 cells: TS-BGT28(xxx)-G12 (xxx=285-305, in steps of 5)


**TÜV NORD CERT GmbH**
Certification Body
Consumer Products

56 cells: SS-BGxxx-28MDH-G12(T) (xxx=285-305, in steps of 5)
 48 cells: TS-BGT24(xxx)-G12 (xxx=245-265, in steps of 5)
 48 cells: SS-BGxxx-24MDH-G12(T) (xxx=245-265, in steps of 5)
 Remark: xxx indicates rated output power generated from front side only at STC.

Maximum system voltage: 1500V
 Maximum overcurrent protection rating: 35A
 Electrical protection class: Class II
 Pollution degree: 1
 98th percentile module operating temperature (T₉₈): 70°C
 Design load (positive / negative): 3600Pa / 1600Pa, refer CDF for details
 Safety factors: 1.5
 Fire safety class: Class A or Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Module types: **Double Glass PV Modules with Half-cut 182.2mm x 191.6mm TOPCon Mono-crystalline Silicon Solar Cells:**
 144 cells: TS-BGT72(xxx)-G10(xxx = 595-615, in steps of 5)
 144 cells: SS-BGxxx-72MDH-G10(T)(xxx = 595-615, in steps of 5)
 132 cells: TS-BGT66(xxx)-G10(xxx = 545-560, in steps of 5)
 132 cells: SS-BGxxx-66MDH-G10(T)(xxx = 545-560, in steps of 5)
 120 cells: TS-BGT60(xxx)-G10(xxx = 495-510, in steps of 5)
 120 cells: SS-BGxxx-60MDH-G10(T)(xxx = 495-510, in steps of 5)
 108 cells: TS-BGT54(xxx)-G10(xxx = 445-460, in steps of 5)
 108 cells: SS-BGxxx-54MDH-G10(T)(xxx = 445-460, in steps of 5)
 Remark: xxx indicates rated output power generated from front side only at STC.

Maximum system voltage: 1500V
 Maximum overcurrent protection rating: 30A
 Electrical protection class: Class II
 Pollution degree: 1
 98th percentile module operating temperature (T₉₈): 70°C
 Design load (positive / negative): 3600Pa / 1600Pa, refer CDF for details
 Safety factors: 1.5



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Fire safety class:	Class A or Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)
Module types:	Double Glass PV Modules with Half-cut 182.2mm x 199mm TOPCon Mono-crystalline Silicon Solar Cells: 144 cells: TS-BGT72(xxx)-G13 (xxx = 615-640, in steps of 5) 144 cells: SS-BGxxx-72MDH-G13(T)(xxx = 615-640, in steps of 5) 132 cells: TS-BGT66(xxx)-G13 (xxx = 565-585, in steps of 5) 132 cells: SS-BGxxx-66MDH-G13(T)(xxx = 565-585, in steps of 5) 120 cells: TS-BGT60(xxx)-G13(xxx = 515-530, in steps of 5) 120 cells: SS-BGxxx-60MDH-G13(T)(xxx = 515-530, in steps of 5) 108 cells: TS-BGT54(xxx)-G13(xxx = 460-480, in steps of 5) 108 cells: SS-BGxxx-54MDH-G13(T)(xxx = 460-480, in steps of 5) Remark: xxx indicates rated output power generated from front side only at STC.
Maximum system voltage:	1500V
Maximum overcurrent protection rating:	30A
Electrical protection class:	Class II
Pollution degree:	1
98th percentile module operating temperature (T ₉₈)	70°C
Design load (positive / negative):	3600Pa / 1600Pa, refer CDF for details
Safety factors:	1.5
Fire safety class:	Class A or Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Module types:	Double Glass PV Modules with Half-cut 182.2mm x 210mm TOPCon Mono-crystalline Silicon Solar Cells: 132 cells: TS-BGT66(xxx)-G11(xxx = 595-620, in steps of 5) 132 cells: SS-BGxxx-66MDH-G11(T) (xxx = 595-620, in steps of 5) 120 cells: TS-BGT60(xxx)-G11(xxx = 545-565, in steps of 5) 120 cells: SS-BGxxx-60MDH-G11(T)(xxx = 545-565, in steps of 5) 108 cells: TS-BGT54(xxx)-G11(xxx = 485-505, in steps of 5) 108 cells: SS-BGxxx-54MDH-G11(T)(xxx = 485-505, in steps of 5) 96 cells: TS-BGT48(xxx)-G11(xxx = 435-450, in steps of 5) 96 cells: SS-BGxxx-48MDH-G11(T)(xxx = 435-450, in steps of 5)
---------------	--

Remark: xxx indicates rated output power generated from front side only at STC.

Maximum system voltage:	1500V
Maximum overcurrent protection rating:	30A
Electrical protection class:	Class II
Pollution degree:	1
98th percentile module operating temperature (T ₉₈)	70°C
Design load (positive / negative):	3600Pa / 1600Pa, refer CDF for details
Safety factors:	1.5
Fire safety class:	Class A or Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Module types:

Double Glass PV Modules with Half-cut 182.2mm x 169.25mm TOPCon Mono-crystalline Silicon Solar Cells:

156 cells: TS-BGT78(xxx)-G7(xxx = 560-595, in steps of 5)

156 cells: SS-BGxxx-78MDH-G7(T)(xxx = 560-595 in steps of 5)

144 cells: TS-BGT72(xxx)-G7(xxx = 515-550, in steps of 5)

144 cells: SS-BGxxx-72MDH-G7(T)(xxx = 515-550, in steps of 5)

120 cells: TS-BGT60(xxx)-G7(xxx = 430-455, in steps of 5)

120 cells: SS-BGxxx-60MDH-G7(T)(xxx = 430-455, in steps of 5)

Remark: xxx indicates rated output power generated from front side only at STC.

Maximum system voltage:	1500V
Maximum overcurrent protection rating:	30A
Electrical protection class:	Class II
Pollution degree:	1
98th percentile module operating temperature (T ₉₈)	70°C
Design load (positive / negative):	3600Pa / 1600Pa, refer CDF for details
Safety factors:	1.5
Fire safety class:	Class A or Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)



TÜV NORD CERT GmbH
Certification Body
Consumer Products

Module types:

Double Glass PV Modules with Half-cut 182mm x 188mm TOPCon Mono-crystalline Silicon Solar Cells:

144 cells: TS-BGT72(xxx)-G9(xxx = 580-615, in steps of 5)

144 cells: SS-BGxxx-72MDH-G9(T)(xxx = 580-615, in steps of 5)

132 cells: TS-BGT66(xxx)-G9(xxx = 530-560, in steps of 5)

132 cells: SS-BGxxx-66MDH-G9(T)(xxx = 530-560, in steps of 5)

120 cells: TS-BGT60(xxx)-G9(xxx = 485-510, in steps of 5)

120 cells: SS-BGxxx-60MDH-G9(T)(xxx = 485-510, in steps of 5)

108 cells: TS-BGT54(xxx)-G9(xxx = 435-460, in steps of 5)

108 cells: SS-BGxxx-54MDH-G9(T)(xxx = 435-460, in steps of 5)

Remark: xxx indicates rated output power generated from front side only at STC.

Maximum system voltage: 1500V

Maximum overcurrent protection rating: 30A

Electrical protection class: Class II

Pollution degree: 1

98th percentile module operating temperature (T_{98}): 70°C

Design load (positive / negative): 3600Pa / 1600Pa, refer CDF for details

Safety factors: 1.5

Fire safety class: Class A or Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) attached to test report with same file no.

**TÜV NORD CERT GmbH**
Certification Body
Consumer Products